

Model FGT-1000

Product Description

Model No	Nominal Pipe Size		K-Factor	Rated Working Pressure		Remarks
	in	(mm)		psi	(kPa)	
FGT-1000	1, 1 1/4, 1 1/2, 2	(25, 32, 40, 50)	5.6	300	(2065)	a, b
FGT-1000	1, 1 1/4, 1 1/2, 2	(25, 32, 40, 50)	8.0	300	(2065)	a, b

- Remarks:**
- a. Devices supplied with female NPT threaded end connections
 - b. Model FGT-1000 is available in two versions; Model 1 has no plug, Model 2 has a plug on the bottom of the valve

Details

Category	Sprinkler System Alarm Testers
Class of Work	1625 - Branch Line Testers
Approval Standard	FM 1625 - Sprinkler System Alarm Test Devices
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Fireguard Global Ltd
Unit 11, Chancel Industrial Estate, Newhall St, Willenhall WV13 1NX, United Kingdom
<http://fireguard-uk.com>