



Valves | Water Control Valves (OS&Y and NRS Gate Valves) | **Gate Valves, Outside Screw and Yoke**

Models FGO907-365, FGO138-365, FGO135-36,5 FGM939-365, and FGM909-365

Product Description

Resilient Seated Gate Valves. Available with the following sizes, end connections and rated working pressures:

Product Specification

Model No	Valve Size		Rated Working Pressure		End Connection
	in	(mm)	psi	(kPa)	
FGO907-365	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	365	(2515)	Flange × Flange (a)
FGO138-365	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	365	(2515)	Flange × Groove (a, b)
FGM909-365	3, 4, 6, 8, 10, 12	(80, 100, 150, 200, 250, 300)	365	(2515)	Flange × Mechanical Joint (a, c)
FGO135-365	2, 2 1/2, 3, 4, 5, 6, 8, 10, 12	(50, 65, 80, 100, 125, 150, 200, 250, 300)	365	(2515)	Groove x Groove (b)
FGM939-365	3, 4, 6, 8, 10, 12	(80, 100, 150, 200, 250, 300)	365	(2515)	Mechanical Joint x Mechanical Joint (c)

- a. Flange Connections are ANSI 125/150, EN1092, AS4087
- b. Groove Connections are AWWA C606
- c. Mechanical Joint Connections are AWWA C153/A21.11-2007

Details

Category	Gate Valves, Outside Screw and Yoke
Class of Work	1120 - OS&Y and NRS Gate Valves
Approval Standard	FM 1120, 1130 - Fire Service Water Control Valves (OS&Y and NRS Type Gate Valves)
Certification Type	FM Approved
Listing Country	United Kingdom

Company

Fireguard Global Ltd
Unit 11, Chancel Industrial Estate,
Newhall St, Willenhall WV13 1NX,
United Kingdom
<http://fireguard-uk.com>