

Kitemark™ Certificate

This is to certify that:

Fireguard Global Limited
Unit 11, Chancel Industrial Estate
Newhall Street
Willenhall
WV13 1NX
United Kingdom

Holds Certificate Number:

KM 591532

In respect of:

BS EN 3
Portable fire extinguishers

This issues the right and licence to use the Kitemark in accordance with the Kitemark Terms and Conditions governing the use of the Kitemark, as may be updated from time to time by BSI Assurance UK Ltd (the "Conditions"). All defined terms in this Certificate shall have the same meaning as in the Conditions.

The use of the Kitemark is authorized in respect of the Product(s) detailed on this Certificate provided at or from the above address.

For and on behalf of BSI:

Shahm Barhom, Group Product Certification Director

First Issued: 2012-11-30

Latest Issue: 2025-03-26

Effective Date: 2025-05-30

Expiry Date: 2028-05-29

Page: 1 of 4



Kitemark™ Certificate

No. KM 591532

Model No	Description
FGP1	1 kg 70% ABC powder, stored pressure. Fire rating 8A & 34B
FGP2	2 kg 70% ABC powder, stored pressure. Fire rating 13A & 70B
FGP6	6 kg 70% ABC powder, stored pressure. Fire rating 34A & 183B
FGP9	9 kg 70% ABC powder, stored pressure. Fire rating 55B & 233B
FGP1A	1 kg 40% ABC powder, stored pressure. Fire rating 5A & 34B
FGP2A	2 kg 40% ABC powder, stored pressure. Fire rating 13A & 70B
FGP6A	6 kg 40% ABC powder, stored pressure. Fire rating 27A & 144B
FGP9A	9 kg 40% ABC powder, stored pressure. Fire rating 34A & 233B
FGF6	6 litre (3% AFFF) foam, stored pressure. Fire rating 13A & 144B
FGF9	9 litre (3% AFFF) foam, stored pressure. Fire rating 21A & 183B
FGW9	9 litre water, stored pressure. Fire rating 13A
FGC2	2 kg carbon dioxide. Fire rating 34B
FGC5	5 kg carbon dioxide. Fire rating 70B
FGP1R	1 kg 40% ABC powder, stored pressure. Fire rating 8A & 34B
FGFP1	1 kg 40% ABC powder, stored pressure. Fire rating 8A & 34B
FGP2R	2 kg 40% ABC powder, stored pressure. Fire rating 13A & 55B
FGFP2	2 kg 40% ABC powder, stored pressure. Fire rating 13A & 55B
FGP3R	3 kg 40% ABC powder, stored pressure. Fire rating 21A & 70B
FGFP3	3 kg 40% ABC powder, stored pressure. Fire rating 21A & 70B
FGP4R	4 kg 40% ABC powder, stored pressure. Fire rating 27A & 113B
FGP6R	6 kg 40% ABC powder, stored pressure. Fire rating 34A & 183B
FGFP6	6 kg 40% ABC powder, stored pressure. Fire rating 34A & 183B
FGP9R	9 kg 40% ABC powder, stored pressure. Fire rating 43A & 183B
FGFP9	9 kg 40% ABC powder, stored pressure. Fire rating 43A & 183B
FGP12R	12 kg 40% ABC powder, stored pressure. Fire rating 55A & 233B
FGFP12	12 kg 40% ABC powder, stored pressure. Fire rating 55A & 233B
FGC2A	2 kg carbon dioxide, aluminium body. Fire rating 34B

First Issued: 2012-11-30

Latest Issue: 2025-03-26

Effective Date: 2025-05-30

Expiry Date: 2028-05-29

Page: 2 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 591532

Model No	Description
FGFC2	2 kg carbon dioxide, steel body. Fire rating 34B
FGC5A	5 kg carbon dioxide, aluminium body. Fire rating 89B
FGFC5	5 kg carbon dioxide, steel body. Fire rating 89B
FGF6R	6 litre foam (3% AFFF), stored pressure. Fire rating 13A & 144B
FGFF6	6 litre foam (3% AFFF), stored pressure. Fire rating 13A & 144B
FGF9R	9 litre foam (3% AFFF), stored pressure. Fire rating 21A & 233B
FGFF9	9 litre foam (3% AFFF), stored pressure. Fire rating 21A & 233B
FGWC6-F	6 litre wet chemical, stored pressure. Fire rating 13A and 75F
FGWC9-F	9 litre wet chemical, stored pressure. Fire rating 13A and 75F
FGWC9-FR	9 litre wet chemical, stored pressure. Fire rating 21A and 75F
FGFP1m	1 kg ABC powder, stored pressure. Fire rating 8A & 55B
FGFP1s	1 kg ABC powder (25% MAP), stored pressure. Fire rating 5A & 34B
FGFP2m	2 kg ABC powder, stored pressure. Fire rating 13A & 89B
FGFP4m	4 kg ABC powder, stored pressure. Fire rating 27A & 183B
FGFP6m	6 kg ABC powder, stored pressure. Fire rating 43A & 233B
FGFP9m	9 kg ABC powder, stored pressure. Fire rating 55A & 233B
FGFP6s	6 kg powder, stored pressure. Fire rating 55A & 233B
FGFP6sa	6 kg powder, stored pressure. Fire rating 55A & 233B
FGFP6sb	6 kg powder, stored pressure. Fire rating 43A & 233B
FGF6m	6 litre foam stored pressure. Fire rating 27A & 183B
FGF6s	6 litre foam, stored pressure. Fire rating 21A & 183B
FGF9m	9 litre foam, stored pressure. Fire rating 34A & 233B
FGF9s	9 litre foam, stored pressure. Fire rating 27A & 233B
FGW6m	6 litre water, stored pressure. Fire rating 13A
FGW6s	6 litre water + additive (5.1 litre water + 0.9 litre INILAM AX), stored pressure. Fire rating 34A
FGW9m	9 litre water, stored pressure. Fire rating 21A
FGWC2	2 litre wet chemical, stored pressure. Fire rating 5A, 70B & 25F

First Issued: 2012-11-30

Latest Issue: 2025-03-26

Effective Date: 2025-05-30

Expiry Date: 2028-05-29

Page: 3 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.

To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).

Kitemark™ Certificate

No. KM 591532

Model No	Description
FGWC3	3 litre wet chemical, stored pressure. Fire rating 13A, 89B & 40F
FGWC6	6 litre wet chemical, stored pressure. Fire rating 34A, 233B & 75F
FGC2m	2 kg carbon dioxide. Fire rating 34B
FGC5m	5 kg carbon dioxide. Fire rating 89B
FGC2s	2 kg carbon dioxide. Fire rating 34B
FGC5s	5 kg carbon dioxide. Fire rating 70B
FGHFC-2	2 kg clean agent (HFC-236fa), stored pressure. Fire rating 21B
FGHFC-4	4 kg clean agent (HFC-236fa), stored pressure. Fire rating 34B
FGHFC-6	6 kg clean agent (HFC-236fa), stored pressure. Fire rating 34B
FGHFC-9	9 kg clean agent (HFC-236fa), stored pressure. Fire rating 55B
FGFM-2	2 litre foam mist, stored pressure, stainless steel cylinder. Fire rating 5A, 55B & 25F
FGFM-6	6 litre foam mist, stored pressure, stainless steel cylinder. Fire rating 13A, 144B, 40F
FGWM-2	2 litre water mist, stored pressure, stainless steel cylinder. Fire rating 5A & 25F
FGWM-3	3 litre water mist, stored pressure, stainless steel cylinder. Fire rating 8A & 25F
FGWM-6	6 litre water mist, stored pressure, stainless steel cylinder. Fire rating 13A & 75F
FGWM-9	9 litre water mist, stored pressure, stainless steel cylinder. Fire rating 21A & 75F
FGW6-C	6 litre water, stored pressure. Fire rating 13A
FGW9-C	9 litre water, stored pressure. Fire rating 21A
FGWC3	3 litre wet chemical, stored pressure. Fire rating 8A & 40F
FGWC6	6 litre wet chemical, stored pressure. Fire rating 13A & 75F
FGWC9	9 litre wet chemical, stored pressure. Fire rating 21A & 75F
FGF3-C	3 litre foam (6%), stored pressure. Fire rating 8A & 89B
FGF6-C	6 litre foam (6%), stored pressure. Fire rating 13A & 144B
FGF9-C	9 litre foam (6%), stored pressure. Fire rating 21A & 233B

All the above products are certified to **BS EN 3-7:2004+A1:2007**

First Issued: 2012-11-30

Latest Issue: 2025-03-26

Effective Date: 2025-05-30

Expiry Date: 2028-05-29

Page: 4 of 4

This certificate has been issued by and remains the property of BSI Assurance UK Ltd, Kitemark Court, Davy Avenue, Knowlhill, Milton Keynes MK5 8PP, United Kingdom and should be returned immediately upon request.
To check its validity telephone +44 (0) 345 080 9000. An electronic certificate can be authenticated [online](#).