

Certificate of Product Approval

Fireguard Global Ltd

CERTIFICATE NUMBER	ISSUE	COMPANY ADDRESS
1426a-(cl-09)	01	Unit 11, Chancel Industrial Estate Newhall Street Willenhall WV13 1NX United Kingdom

The named company is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirements of the standard(s) detailed below:

PRODUCTS	STANDARDS
Alarm Warning Devices FGC351S IQ321SF (refer to Appendix for details)	EN 54-3:2014 + A1:2019 EN 54-23:2010

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.



Z Major
Verifier

28 January 2026
Date of Issue

28 January 2026
Date of First Issue



This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com



Appendix to Certificate No: 1426a-(cl-09)

ISSUE
01

Fireguard Global Ltd

Certified Product	Description	LPCB Ref No.
FGC351S	Conventional Sounder Beacon (DZ-9091K Base) Notes: 1) Meets the requirements of EN 54-23 at the following: - Category C-3-8 + W-2.4-6 - Flash rate 0.5Hz - One Mode (Light output synchronization) - Flash Colour White - For wall and ceiling mounting 2) Meets the requirements of EN 54-3 at the following tone: - Tone 1: 667Hz - 2000Hz@0.22Hz	1426a/01
IQ321SF	Addressable Sounder Beacon (DZ-9091 Base) Notes: 1)Meets the requirement of EN 54-23 at the following: - Category C-3-8 + W-2.4-6 - Flash Rate 0.5Hz - One Mode (Light output synchronization) - Flash Colour White - For wall and ceiling mounting 2) Meets the requirements of EN 54-3 at the following tone: - Tone 1: 667Hz - 2000Hz@0.22Hz	1426a/02

Products Extras

DZ-9091K
DZ-9091

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.

	Z Major	28 January 2026
Signed for BRE Global Ltd	Verifier	Date of Issue
28 January 2026		
Date of First Issue		



This certificate and appendix remain the property of BRE. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

