

Certificate of Product Approval


Fireguard Global Ltd

CERTIFICATE NUMBER	ISSUE	COMPANY ADDRESS
1935a	01	Unit 11 Chancel Ind Estate Newhall Street Willenhall West Midlands WV13 1NX United Kingdom

The named company is authorised to use the LPCB mark in association with the product(s) listed in this certificate having complied with the requirements of the standard(s) detailed below:

PRODUCTS	STANDARDS (see appendix for details)
Fireguard FG FRC 180	SD024 incorporating the following standards: BS 6387:2013 (Category CWZ) EN 61034-2:2005+A2:2020 EN 60754-1:2014 EN 50200:2015 (Class PH120) EN 50200:2015 (Annex E)
Fire Resistant Cables	

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.



Signed for BRE Global Ltd

Obada Piracha

Senior Certification Manager

14 August 2026

Date of Issue

14 August 2026

Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com



Appendix to Certificate No: 1935a

ISSUE

01

Fireguard Global Ltd


Product name						LPCB Ref. No.
Fireguard FG FRC 180						1935a/01
Model Number	Nominal csa of conductor (mm ²)	Core Construction	BS 6387	EN 60754-1	EN 61034-2	EN 50200
FRC-180-82	1.5 ⁽¹⁾	2	CWZ	<0.5% HCl	>60%	PH120 & Annex E
FRC180-83	2.5 ⁽¹⁾	2	CWZ	<0.5% HCl	>60%	PH120 & Annex E
FRC180-87	1.5 ⁽²⁾	2	CWZ	<0.5% HCl	>60%	PH120 & Annex E
FRC180-88	2.5 ⁽²⁾	2	CWZ	<0.5% HCl	>60%	PH120 & Annex E
FRC180-78	1.5 ⁽¹⁾	3	CWZ	<0.5% HCl	>60%	PH120 & Annex E
FRC180-86	1.5 ⁽¹⁾	4	CWZ	<0.5% HCl	>60%	PH120 & Annex E

Uo/U 300/500V

Notes:

1. Solid conductor only.
2. Stranded conductor.

This certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 certificate being maintained.



	Obada Piracha	14 August 2026
Signed for	Senior Certification Manager	Date of Issue

14 August 2026
Date of First Issue



This certificate and appendix remain the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit www.redbooklive.com). To check the validity of this certificate and appendix please scan the QR tag, visit www.redbooklive.com or contact us.

LPCB® is a registered trademark of the Building Research Establishment Ltd.

BRE Global, Bucknalls Lane,
Watford, WD25 9XX
T: +44 (0)333 321 8811
E: enquiries@bregroup.com

